

Product Data Sheet

DOW FILMTEC[™] BW30HR-440 Element

| Description | Ideal for: reverse osmosis plant managers and operators dealing with controlled pre-treatment waters and seeking consistency, high performance, long element life, increase productivity, higher water quality coupled with excellent fouling resistance and reduced footprint installations. |
|--------------|--|
| | With proven performance, DOW FILMTEC[™] BW30HR-440: Delivers the highest quality permeate water while minimizing CAPEX and OPEX Offers increased active area with the most effective cleaning performance, robustness and durability due to its widest cleaning pH range (1-13) and chemical tolerance and the support of Dow technical representatives |
| Product Type | Spiral-wound element with polyamide thin-film composite membrane |


| Product Sp | ecifications |
|-------------------|--------------|
|-------------------|--------------|

| | A | A | Faced On service | Downsofs | Flaw Data | Typical | Mission Oalt |
|----------------------|-----------------|----------------|--------------------------------|----------|----------------------------------|----------------------------------|-------------------------------|
| DOW FILMTEC™ Element | Active (ft²) | e Area (m²) | Feed Spacer Thickness (mil) | (GPD) | Flow Rate (m ³ /d) | Stabilized Salt Rejection (%) | Minimum Salt Rejection (%) |
| BW30HR-440 | 440 | 41 | 28 | 12,650 | 48 | 99.7 | 99.4 |

1. Permeate flow and salt (NaCl) rejection based on the following standard test conditions: 2,000 ppm NaCl, 225 psi (15.5 bar), 77°F (25°C), pH 8, 15% recovery.

- Flow rates for individual elements may vary but will be no more than ±15%.
 Stabilized salt rejection is generally achieved within 24-48 hours of continuous use; depending upon feedwater characteristics and operating conditions.
- Sales specifications may vary as design revisions take place. 4.

Active area guaranteed ± 3%. Active area as stated by Dow Water & Process Solutions is not comparable to nominal 5. membrane area often stated by some manufacturers. Measurement method described in Form No. 609-00434.



1. Refer to Dow Water & Process Solutions Design Guidelines for multiple-element applications. 1 inch = 25.4 mm

Element to fit nominal 8-inch (203-mm) I.D. pressure vessel. 2.

| Operating and | Maximum Operating Temperature ^a | 113°F (45°C) | | | | | |
|--|--|--|--|--|--|--|--|
| Cleaning Limits | Maximum Operating Pressure | 600 psig (41 bar) | | | | | |
| | Maximum Element Pressure Drop | 15 psig (1.0 bar) | | | | | |
| | pH Range, Continuous Operation ^a | 2 – 11 | | | | | |
| | pH Range, Short-Term Cleaning (30 min.) ^b | 1 – 13 | | | | | |
| | Maximum Feed Silt Density Index (SDI) | SDI 5 | | | | | |
| | Free Chlorine Tolerance ^c | < 0.1 ppm | | | | | |
| | ^a Maximum temperature for continuous operation above pH 10 is 95°F (3 | 35°C). | | | | | |
| | ^b Refer to Cleaning Guidelines in specification sheet 609-23010. | in a state will a state a state and the state of the stat | | | | | |
| | ^c Under certain conditions, the presence of free chlorine and other oxidizing agents will cause premature membrane failure. Since oxidation damage is not covered under warranty, Dow Water & Process Solutions recommends removing residual free chlorine by pretreatment prior to membrane exposure. Please refer to technical bulletin <u>"Dechlorinating Feedwater"</u> for more information. | | | | | | |
| Additional Important | Before use or storage, review these additional | resources for important information: | | | | | |
| Information | Usage Guidelines for DOW FILMTEC™ 8" Elements | | | | | | |
| | <u>System Operation: Initial Start-Up</u> | | | | | | |
| Regulatory Note | These membranes may be subject to drinking countries; please check the application status | •• | | | | | |
| Product Stewardship | Dow has a fundamental concern for all who make, distribute, and use its products, and for the environment in which we live. This concern is the basis for our product stewardship philosophy by which we assess the safety, health, and environmental information on our products and then take appropriate steps to protect employee and public health and our environment. The success of our product stewardship program rests with each and every individual involved with Dow products—from the initial concept and research, to manufacture, use, sale, disposal, and recycle of each product. | | | | | | |
| Customer Notice | Dow strongly encourages its customers to review both their manufacturing processes and their applications of Dow products from the standpoint of human health and environments quality to ensure that Dow products are not used in ways for which they are not intended tested. Dow personnel are available to answer your questions and to provide reasonable technical support. | | | | | | |
| DOW FILMTEC [™] Membranes Contact Dow Water & Process Solutions: | | arily guarantee the removal of cysts and pathogens from water. nplete system design and on the operation and maintenance of | | | | | |
| North America: 1-800-447-4369 Latin America: (+55) 11-5188-9222 Europe: +800-3-694-6367 Italy: +800-783-825 South Africa: +0800 99 5078 Pacific: +800 7776 7776 China: +400 889-0789 http://www.dowwaterandprocess.com | applicable laws may differ from one location to another and m whether products and the information in this document are ap workplace and disposal practices are in compliance with applica in this literature may not be available for sale and/or available may not have been approved for use in all countries. Dow assu References to "Dow" or the "Company" mean the Dow legal en | by Dow or others is to be inferred. Because use conditions and nay change with time, Customer is responsible for determining propriate for Customer's use and for ensuring that Customer's able laws and other government enactments. The product shown in all geographies where Dow is represented. The claims made mes no obligation or liability for the information in this document. tity selling the products to Customer unless otherwise expressly ARRANTIES OF MERCHANTABILITY OR FITNESS FOR A | | | | | |

