

## GRO ENCAPSULATED ELEMENT HIGH RECOVERY MEMBRANE

PROVIDES HIGH QUALITY REVERSE OSMOSIS WATER

---



**Pentair TLC Residential Membranes use an industry leading state-of-the-art TLC (Thin Layer Composite) membrane providing high quality water for a broad range of water chemistries. Each membrane is required to meet our factory's strict performance requirements prior to shipment.**

### FEATURES/BENEFITS

---

Double the recovery over standard reverse osmosis elements

Rejection performance comparable to standard reverse osmosis elements

High rejection stability at high input TDS

TLC Thin Layer Composite membrane

100% dry membrane maximizing shelf life

### OPERATIONAL LIMITS

---

Maximum Pressure:  
125 PSI (6.90 bar)

Maximum Temperature:  
120°F (49°C)

pH:  
4-11

Free Chlorine:  
0.1 ppm

Filters and membrane elements are not to be installed on microbiologically unsafe water supplies. TLC Membranes are not certified to sanitize water, remove cysts, bacteria, or viruses. Filter and membrane element performance can be affected by fluctuations in water quality.



## SIZE SPECIFICATIONS



## PRODUCT PERFORMANCE

PART NUMBER	MODEL NUMBER	NOMINAL PERFORMANCE		DRAIN FLOW CONTROL (ML/MIN)
		FLOW* GDP (LPD)	REJECTION	
4002573	GRO-36EN	36 (136)	96	100
4002574	GRO-50EN	50 (189)	96	150
4002575	GRO-75EN	75 (284)	96	200

Product Tested at 65 psi; 77°F; 50% recovery; 500 ppm NaCl/RO

NOTE: The data above is based on internal laboratory testing

Nominal performances are based on a 500 ppm softened tap at 65 psig (4.48 bar), 77°F (25°C), 50% recovery after 25 hours. Individual element flux may vary +/- 15%.

## SHIPPING SPECIFICATIONS

PART #	MODEL #	CARTON DIMENSIONS - INCHES (CM)	WEIGHT LBS. (KG)	CARTON QTY.
4002573	GRO-36EN	11.5" L x 12" W x 17" H (29.2 x 30.5 x 43.1)	25.2 lbs. (11.4)	16
4002574	GRO-50EN	11.5" L x 12" W x 17" H (29.2 x 30.5 x 43.1)	26 lbs. (11.8)	16
4002575	GRO-75EN	11.5" L x 12" W x 17" H (29.2 x 30.5 x 43.1)	27.7 lbs. (12.56)	16
<b>PALLET</b>		40" L x 48" W x 37" H (101.6 x 121.9 x 93.9)	384 pcs.	



The GRO-36EN, GRO-50EN and GRO-75EN are Tested and Certified by NSF International against NSF/ANSI Standard 58 for materials and structural integrity requirements



### PENTAIR WATER QUALITY SYSTEMS

5730 NORTH GLEN PARK ROAD, MILWAUKEE, WI 53209  
P: 262.238.4400 | F: 262.238.4404

WATERPURIFICATION.PENTAIR.COM

CUSTOMER CARE: 800.279.9404 | tech-support@pentair.com

© 2015 Pentair Residential Filtration, LLC. All rights reserved.

4002874 REV A MR15